

000 ЧЖ - Гродненская область
 ПОЛНОЕ ИМЯ ПОТРЕБИТЕЛЯ: Юнко Илья
 АДРЕС УСТАНОВКИ: Радужная д 18

Подача+Р Система 1

ТЭН-104 Зав.И 1551476
 G1 ДУ50 0.150 - 60.00 м3/ч
 G2 ДУ50 0.150 - 60.00 м3/ч
 Q = MI(hn - ho)

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ
 за период с 21/11/22 по 20/12/22

ДАТА дд/мм/гг	Q Гкал	MI т	M2 т	MI-M2 т	Tn С	To С	Pn МПа	Po МПа	Tнар,ч час
21/11/22	8.045	316.06	305.87	+10.19	84.29	58.94	0.91	0.51	23.99
22/11/22	7.636	307.54	298.81	+8.72	83.25	58.53	0.91	0.51	24.00
23/11/22	6.584	234.10	227.43	+6.68	82.04	54.02	0.91	0.51	24.00
24/11/22	6.622	222.42	216.25	+6.17	82.70	53.03	0.91	0.51	24.00
25/11/22	7.307	236.07	228.44	+7.63	85.13	54.29	0.91	0.51	24.00
26/11/22	7.224	237.48	230.73	+6.75	84.62	54.31	0.91	0.51	24.00
27/11/22	7.218	234.78	228.30	+6.48	84.36	53.72	0.91	0.51	24.00
ИТОГО:	50.64	1768.5	1735.8	+32.6	83.78	55.57	0.91	0.51	168.0
28/11/22	7.070	226.61	220.68	+5.93	84.03	52.93	0.91	0.51	24.00
29/11/22	7.407	238.97	232.95	+6.01	85.66	54.77	0.91	0.51	24.00
30/11/22	8.436	280.57	272.44	+8.13	88.86	58.91	0.91	0.51	24.00
01/12/22	9.070	297.54	288.29	+9.25	91.11	60.75	0.91	0.51	24.00
02/12/22	8.521	252.25	245.40	+6.85	92.29	58.64	0.91	0.51	24.00
03/12/22	8.579	252.70	245.19	+7.51	91.96	58.14	0.91	0.51	24.00
04/12/22	8.498	248.57	241.83	+6.74	91.46	57.40	0.91	0.51	24.00
ИТОГО:	57.58	1797.2	1746.8	+50.4	89.47	57.55	0.91	0.51	168.0
05/12/22	9.024	274.37	267.10	+7.26	92.70	59.94	0.91	0.51	24.00
06/12/22	8.692	254.32	245.10	+9.22	92.60	58.55	0.91	0.51	24.00
07/12/22	8.646	253.51	244.47	+9.04	91.70	57.71	0.91	0.51	24.00
08/12/22	8.460	254.56	246.09	+8.47	91.33	58.22	0.91	0.51	24.00
09/12/22	7.525	204.19	197.02	+7.18	90.89	54.16	0.91	0.51	24.00
10/12/22	7.167	193.18	185.71	+7.47	89.39	52.41	0.91	0.51	24.00
11/12/22	6.697	176.41	168.81	+7.60	88.56	50.71	0.91	0.51	24.00
ИТОГО:	56.21	1610.5	1554.3	+56.2	91.23	56.46	0.91	0.51	168.0
12/12/22	---	---	---	---	---	---	---	---	---
13/12/22	---	---	---	---	---	---	---	---	---
14/12/22	---	---	---	---	---	---	---	---	---
15/12/22	---	---	---	---	---	---	---	---	---
16/12/22	---	---	---	---	---	---	---	---	---
17/12/22	---	---	---	---	---	---	---	---	---
18/12/22	---	---	---	---	---	---	---	---	---
ИТОГО:	0.00	0.0	0.0	+0.0	0.00	0.00	0.00	0.00	0.0
19/12/22	---	---	---	---	---	---	---	---	---
20/12/22	---	---	---	---	---	---	---	---	---
ИТОГО:	0.00	0.0	0.0	+0.0	0.00	0.00	0.00	0.00	0.0
ИТОГО:	164.43	5196.2	5036.9	+159.3	88.06	56.53	0.91	0.51	504.0
		+159.29		-0	31.53				

Общее время работы системы, ч = Tнар. + Tmin + Tmax + Tdtain + Tтн.
 744.00 503.99 0.00 0.00 0.00 216.01
 Количество тепла, Гкал Q = Qt/c + Qmin + Qmax + Qсм. + Qt/в + Qсан.ут.
 = 164.43 + + + + +

Показания интеграторов на	20/11/22 24:00	11/12/22 24:00	Разность	12/12/22 10:34
Расход тепла Q, Гкал	6542.254	6706.681	164.427	6709.114
Расход теплоносителя MI, т	205192.43	210388.62	5196.19	210454.50
Расход теплоносителя M2, т	207144.56	212181.47	5036.90	212245.04
Время наработки Tнар, ч	37070.47	37574.46	503.99	37585.03
Время неработы Tнер = Tmax + Tmin + Tdt + Tтн, ч			216.01	

вЗА.11
 Подпись потребителя 

Подпись поставщика _____