

НОМЕР АБОНЕНТА:
АДРЕС УСТАНОВКИ:

000 К- Строительная компания
Киев, Радужное д.18

ТЭП-104 Зав.№ 1551476
Б1 ДУ50 0,150 - 60,00 м3/ч
Б2 ДУ50 0,150 - 60,00 м3/ч
Q = M1(hн - hо)

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ
за период с 21/10/22 по 20/11/22

ДАТА	Q	M1	M2	M1-M2	Tn	To	Pn	Рo	Tнар,ч
дд/мм/гг	Гкал	т	т	т	С	С	МПа	МПа	час
21/10/22	5.999	234.10	228.30	+5.80	78.69	53.15	0.91	0.51	23.99
22/10/22	5.497	209.70	204.28	+5.42	77.99	51.86	0.91	0.51	24.00
23/10/22	5.930	239.08	233.71	+5.37	77.05	52.34	0.91	0.51	24.00
24/10/22	5.692	221.80	216.48	+5.32	77.72	52.15	0.91	0.51	24.00
25/10/22	6.567	318.55	311.70	+6.84	75.82	55.29	0.91	0.51	24.00
26/10/22	6.205	285.54	278.56	+6.99	75.57	53.93	0.91	0.51	24.00
27/10/22	5.971	267.94	260.64	+7.30	75.90	53.70	0.91	0.51	24.00
ИТОГО:	41.86	1776.7	1733.7	+43.0	76.83	53.36	0.91	0.51	168.0
28/10/22	5.243	221.22	214.85	+6.37	76.34	52.73	0.91	0.51	24.00
29/10/22	4.815	188.56	182.81	+5.75	76.28	50.84	0.91	0.51	24.00
30/10/22	5.435	230.48	223.93	+6.55	75.99	52.50	0.91	0.51	24.00
31/10/22	6.538	284.99	277.81	+7.18	77.72	54.87	0.91	0.51	24.00
01/11/22	6.588	240.75	233.42	+7.33	81.27	54.00	0.91	0.51	24.00
02/11/22	6.495	234.14	226.84	+7.30	81.49	53.85	0.91	0.51	24.00
03/11/22	7.268	296.33	289.38	+6.95	80.89	56.46	0.91	0.51	24.00
ИТОГО:	42.38	1696.5	1649.0	+47.4	78.72	53.84	0.91	0.51	168.0
04/11/22	7.521	312.56	305.52	+7.04	81.50	57.51	0.91	0.51	24.00
05/11/22	7.176	281.39	273.41	+7.98	81.39	55.99	0.91	0.51	24.00
06/11/22	7.334	273.54	266.50	+7.04	81.93	55.26	0.91	0.51	24.00
07/11/22	6.764	257.93	250.21	+7.72	80.67	54.54	0.91	0.51	24.00
08/11/22	6.237	224.03	216.07	+7.96	80.82	53.08	0.91	0.51	24.00
09/11/22	5.273	173.40	165.90	+7.50	80.95	50.24	0.91	0.51	24.00
10/11/22	5.105	165.62	158.90	+6.72	80.76	50.04	0.91	0.51	24.00
ИТОГО:	43.41	1689.9	1639.5	+50.4	81.16	54.39	0.91	0.51	168.0
11/11/22	4.969	162.38	157.10	+5.28	80.76	50.26	0.91	0.51	24.00
12/11/22	4.741	168.78	163.62	+5.16	78.89	50.90	0.91	0.51	24.00
13/11/22	5.278	186.31	180.54	+5.77	78.84	50.61	0.91	0.51	24.00
14/11/22	6.814	265.90	257.92	+7.98	80.99	55.06	0.91	0.51	24.00
15/11/22	7.189	278.06	269.98	+8.07	82.28	56.53	0.91	0.51	24.00
16/11/22	7.678	306.95	299.97	+6.98	83.18	58.27	0.91	0.51	24.00
17/11/22	8.098	337.73	329.36	+8.36	84.18	60.31	0.91	0.51	24.00
ИТОГО:	44.77	1706.1	1658.5	+47.6	81.70	55.57	0.91	0.51	168.0
18/11/22	8.493	395.01	384.27	+10.74	83.94	62.54	0.91	0.51	24.00
19/11/22	8.589	359.25	348.08	+11.16	84.70	60.89	0.91	0.51	24.00
20/11/22	8.020	313.98	304.32	+9.66	83.83	58.39	0.91	0.51	24.00
ИТОГО:	25.10	1068.2	1036.7	+31.6	84.16	60.77	0.91	0.51	72.0
ИТОГО:	199.52	7736.4	7716.4	+220.0	80.19	55.15	0.91	0.51	744.0
		+220.00		-0	25.04				

Общее время работы системы, ч = Tнар. + Tmin + Tmax + Tdтmin + Tтн.
744.00 743.99 0.00 0.00 0.00 0.01

Количество тепла, Гкал Q = Qт/с + Qmin + Qmax + Qсов. + Qт/в + Qсан.ут.
_____ = 199.52 + _____ + _____ + _____ + _____ + _____

Показания интеграторов на	20/10/22 24:00	20/11/22 24:00	Разность		21/11/22 09:25
Расход тепла Q, Гкал	6342.732	6542.254	199.522	:	6545.332
Расход теплоносителя M1, т	197256.03	205192.43	7936.39	:	205318.62
Расход теплоносителя M2, т	199428.17	207144.56	7716.40	:	207266.85
Время наработки Tнар, ч	36326.48	37070.47	743.99	:	37079.89
Время неработы Tнер = Tmax + Tmin + Tдт + Tтн, ч			0.01	:	

в.А.11
Подпись потребителя _____

Подпись поставщика _____