

АДРЕС: Прокля 6
 ОРГАНИЗАЦИЯ: _____ НОМЕР АБОНЕНТА: _____
 ТИП ТСЧ: ПАТКА НОМЕР ТСЧ: ИТ910068

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ СИСТЕМЫ 1 Тепло. Закрытая 2 канальная
 за период с 21/09/20 по 20/10/20

пер

ДАТА	ЭНЕРГИЯ	МАССА		ТЕМПЕРАТУРА				ДАВЛЕНИЕ		НАРАБ.	Уточка	Поднес	КОД ОШИБКИ
	E, Гкал	M1, тонн	M2, тонн	t1, град.С	t2, град.С	dt, град.С	txв, град.С	P1, атм.	P2, атм.				
21/09	0.000	0.000	0.000	19.22	18.12	1.10	---	---	---	24.00	0.000	0.000	-
22/09	0.000	0.000	0.000	19.96	18.91	1.04	---	---	---	24.00	0.000	0.000	-
23/09	0.000	0.000	0.000	20.26	19.20	1.06	---	---	---	24.00	0.000	0.000	-
24/09	0.000	0.000	0.000	20.52	19.61	0.91	---	---	---	24.00	0.000	0.000	-
25/09	1.098	296.010	297.540	34.34	31.69	2.65	---	---	---	23.95	0.000	1.531	3
26/09	1.266	470.659	473.031	37.90	35.21	2.70	---	---	---	24.00	0.000	2.372	-
27/09	1.597	470.481	472.853	41.72	38.32	3.40	---	---	---	24.00	0.000	2.372	-
28/09	1.003	300.787	302.287	39.06	33.61	5.45	---	---	---	23.98	0.000	1.499	3
29/09	0.000	0.000	0.000	37.02	22.46	14.56	---	---	---	24.00	0.000	0.000	-
30/09	0.001	0.042	0.000	32.15	21.93	10.22	---	---	---	24.00	0.042	0.000	-
01/10	0.000	0.000	0.000	27.35	21.86	5.49	---	---	---	24.00	0.000	0.000	-
02/10	0.000	0.000	0.000	28.14	22.09	6.05	---	---	---	24.00	0.000	0.000	-
03/10	0.000	0.000	0.000	28.67	22.44	6.23	---	---	---	24.00	0.000	0.000	-
04/10	0.000	0.000	0.000	28.76	22.57	6.19	---	---	---	24.00	0.000	0.000	-
05/10	0.000	0.000	0.000	28.69	22.65	6.04	---	---	---	24.00	0.000	0.000	-
06/10	0.000	0.000	0.000	28.68	22.68	6.00	---	---	---	24.00	0.000	0.000	-
07/10	0.000	0.006	0.000	28.73	22.71	6.02	---	---	---	24.00	0.006	0.000	-
08/10	0.000	0.000	0.000	29.99	23.15	6.83	---	---	---	24.00	0.000	0.000	-
09/10	1.303	260.321	261.700	38.81	33.11	5.70	---	---	---	24.00	0.000	1.379	-
10/10	1.805	386.297	388.343	43.39	38.71	4.68	---	---	---	24.00	0.000	2.046	-
11/10	1.767	387.382	389.444	43.46	38.89	4.57	---	---	---	24.00	0.000	2.062	-
12/10	1.849	443.978	446.403	43.92	39.70	4.22	---	---	---	24.00	0.000	2.425	-
13/10	1.879	475.988	478.550	44.24	40.28	3.96	---	---	---	24.00	0.000	2.562	-
14/10	1.853	475.650	478.209	44.74	40.83	3.90	---	---	---	24.00	0.000	2.559	-
15/10	1.797	476.133	478.677	44.01	40.23	3.78	---	---	---	24.00	0.000	2.544	-
16/10	1.754	473.381	475.920	42.77	39.05	3.71	---	---	---	24.00	0.000	2.538	-
17/10	1.782	470.102	472.628	41.88	38.08	3.80	---	---	---	24.00	0.000	2.526	-
18/10	1.919	467.330	469.848	42.42	38.30	4.12	---	---	---	24.00	0.000	2.518	-
19/10	2.849	468.124	470.786	50.39	44.30	6.10	---	---	---	24.00	0.000	2.663	-
20/10	2.600	466.433	468.978	48.43	42.85	5.58	---	---	---	24.00	0.000	2.545	-
Итого	28.121	6789.103	6825.195	35.32	30.45	4.87	---	---	---	719.93	0.048	36.140	-

	норма	0<Gmin	0>Gmax	dt:zmin	неиспр.	итого
T	719.93	0.00	0.00	0.07	0.00	720.00
Ерасч.	28.121					

Дата распечатки: 22/10/20 10:42
 Настройки ТСЧ: min(t1-t2)=0.5 град.С

ПОКАЗАНИЯ ИНТЕГРАТОВ

	ДАТА	ЭНЕРГИЯ E, Гкал	МАССА M1, т	M2, т	НАРАБОТКА Tr, час
Начало периода	21/09	7729.546	969461.931	973465.390	83200.97
Конец периода	20/10	7757.667	976251.039	980290.591	83920.90
РАЗНОСТЬ:		28.121	6789.109	6825.200	719.933

ПРЕДСТАВИТЕЛЬ
 АБОНЕНТА:



ПРЕДСТАВИТЕЛЬ ТЕПЛОСНАБЖАЮЩЕЙ
 ОРГАНИЗАЦИИ: