

АИФЭС: Франкшан 86  
 ОРГАНИЗАЦИЯ: ООО ЧК. СБАН  
 ТИП ТСЧ: МАГИКА      НОМЕР АБОНЕНТА: 000-ЧК.СБАН  
 НОМЕР ТСЧ: МТ910038

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ СИСТЕМЫ 2 ГВС  
 за период с 21/08/20 по 20/09/20 пер

ДАТА	ЭНЕРГИЯ		МАССА		ТЕМПЕРАТУРА			ДАВЛЕНИЕ		НАРАБ.	Утечка	Позмес	КОД ОШИБКИ
	E, Гкал	M1, тонн	M2, тонн	t1, град.С	t2, град.С	dt, град.С	tхв, град.С	F1, атм.	F2, атм.				
21/08	1.687	150.400	139.195	64.26	56.90	7.36	5.00	---	---	24.00	11.205	0.000	-
22/08	1.817	152.274	138.953	64.79	57.42	7.37	5.00	---	---	24.00	13.321	0.000	-
23/08	1.752	151.941	139.665	64.69	57.36	7.33	5.00	---	---	24.00	12.276	0.000	-
24/08	1.709	153.824	141.105	62.95	56.03	6.92	5.00	---	---	24.00	12.718	0.000	-
25/08	1.784	155.184	143.425	65.83	58.40	7.43	5.00	---	---	24.00	11.758	0.000	-
26/08	1.774	155.910	144.804	66.77	59.23	7.54	5.00	---	---	24.00	11.106	0.000	-
27/08	1.818	156.655	144.223	65.92	58.53	7.39	5.00	---	---	24.00	12.432	0.000	-
28/08	1.747	157.090	146.145	66.12	58.72	7.40	5.00	---	---	24.00	10.946	0.000	-
29/08	1.825	157.457	145.406	66.34	58.87	7.47	5.00	---	---	24.00	12.052	0.000	-
30/08	1.869	158.190	144.925	66.12	58.74	7.38	5.00	---	---	24.00	13.265	0.000	-
31/08	1.756	158.086	146.090	65.09	57.98	7.11	5.00	---	---	24.00	11.996	0.000	-
01/09	1.743	157.898	147.955	67.52	59.95	7.56	5.00	---	---	24.00	9.942	0.000	-
02/09	1.877	159.411	147.306	67.67	60.03	7.65	5.00	---	---	24.00	12.105	0.000	-
03/09	1.870	159.046	147.607	68.28	60.51	7.78	5.00	---	---	24.00	11.439	0.000	-
04/09	1.775	159.405	148.349	66.74	59.34	7.40	5.00	---	---	24.00	11.056	0.000	-
05/09	1.752	158.552	146.909	65.40	58.23	7.16	5.00	---	---	24.00	11.644	0.000	-
06/09	1.807	158.062	145.128	65.25	58.08	7.16	5.00	---	---	24.00	12.934	0.000	-
07/09	1.742	159.759	148.222	64.97	57.90	7.08	5.00	---	---	24.00	11.537	0.000	-
08/09	1.655	160.633	148.484	62.76	56.18	6.58	5.00	---	---	24.00	12.149	0.000	-
09/09	1.595	160.766	147.956	59.46	53.36	6.10	5.00	---	---	24.00	12.810	0.000	-
10/09	1.546	160.486	148.707	59.30	53.16	6.14	5.00	---	---	24.00	11.779	0.000	-
11/09	1.563	162.128	150.178	59.15	53.01	6.14	5.00	---	---	24.00	11.950	0.000	-
12/09	1.602	161.406	148.915	59.45	53.20	6.25	5.00	---	---	24.00	12.491	0.000	-
13/09	1.695	162.325	147.140	58.71	52.59	6.11	5.00	---	---	24.00	15.185	0.000	-
14/09	1.674	162.201	148.486	59.08	52.82	6.27	5.00	---	---	24.00	13.716	0.000	-
15/09	1.652	161.428	148.856	60.52	54.03	6.48	5.00	---	---	24.00	12.572	0.000	-
16/09	1.668	161.637	149.757	61.05	54.38	6.66	5.00	---	---	24.00	11.880	0.000	-
17/09	1.757	164.938	151.877	62.42	55.68	6.74	5.00	---	---	24.00	13.061	0.000	-
18/09	1.740	159.953	147.098	62.16	55.32	6.84	5.00	---	---	24.00	12.855	0.000	-
19/09	1.747	161.558	149.021	62.57	55.61	6.96	5.00	---	---	24.00	12.538	0.000	-
20/09	1.923	164.628	147.524	61.04	54.40	6.63	5.00	---	---	24.00	17.103	0.000	-
Итого	53.920	4923.230	4539.407	63.62	56.64	6.98	5.00	---	---	744.00	383.823	0.000	-


	норма	С<Сmin	С>Сmax	dt<min	неиспр.	итого
T	744.00	0.00	0.00	0.00	0.00	744.00
Брасч.	53.920					

Дата распечатки: 22/09/20 10:02  
 Настройки ТСЧ: min(t1-t2)=0.5 град.С

ПОКАЗАНИЯ ИНТЕГРАТОРОВ

	ДАТА	ЭНЕРГИЯ E, Гкал	МАССА M1, т	M2, т	НАРАБОТКА Tr, час
Начало периода	21/08	5019.450	518107.367	475681.301	89525.59
Конец периода	20/09	5073.370	523030.602	480220.713	90269.59
РАЗНОСТЬ:		53.920	4923.234	4539.412	744.000

ПРЕДСТАВИТЕЛЬ  
 АБОНЕНТА:



ПРЕДСТАВИТЕЛЬ ТЕПЛОСНАБЖАЮЩЕЙ  
 ОРГАНИЗАЦИИ: