

P-17 000 "СК - Сибирская Автоматика"

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ
 за период с 21/02/21 по 20/03/21

Кашная, ул. Радужная
 г. 14

ДАТА дд/мм/гг	Q Гкал	M1 т	M2 т	M1-M2 т	Tn С	To С	Fn МПа	Fo МПа	Tнар,ч Час
21/02/21	8.883	253.10	263.75	-10.65	102.60	67.88	0.90	0.51	24.00
22/02/21	9.221	270.27	281.36	-11.08	103.05	69.10	0.90	0.51	24.00
23/02/21	10.657	294.36	306.79	-12.44	110.06	74.07	0.90	0.51	24.00
24/02/21	10.689	310.82	323.59	-12.76	109.44	75.25	0.90	0.51	24.00
25/02/21	4.654	147.71	153.27	-5.56	106.52	75.43	0.90	0.51	24.00
26/02/21	4.772	169.08	173.77	-4.68	82.65	54.56	0.90	0.51	24.00
27/02/21	6.992	239.47	245.74	-6.27	87.69	58.61	0.90	0.51	24.00
ИТОГО:	55.87	1684.8	1748.3	-63.5	101.49	68.56	0.90	0.51	168.0
28/02/21	7.061	240.65	247.37	-6.72	88.77	59.55	0.90	0.51	24.00
01/03/21	6.523	200.69	206.23	-5.54	89.64	57.26	0.90	0.51	24.00
02/03/21	6.211	196.73	202.09	-5.36	88.18	56.72	0.90	0.51	24.00
03/03/21	6.466	193.55	198.85	-5.30	90.23	56.95	0.90	0.51	24.00
04/03/21	6.288	189.27	194.44	-5.16	89.85	56.75	0.90	0.51	24.00
05/03/21	6.908	232.45	238.88	-6.43	88.68	59.08	0.90	0.51	24.00
06/03/21	7.847	317.52	326.82	-9.30	88.01	63.41	0.90	0.51	24.00
ИТОГО:	47.30	1570.9	1614.7	-43.8	88.95	58.96	0.90	0.51	168.0
07/03/21	8.263	324.14	333.78	-9.64	90.60	65.23	0.90	0.51	24.00
08/03/21	8.365	310.65	319.96	-9.31	91.29	64.48	0.90	0.51	24.00
09/03/21	8.774	297.51	306.31	-8.80	96.19	66.83	0.90	0.51	24.00
10/03/21	8.912	269.54	277.57	-8.03	98.71	65.80	0.90	0.51	24.00
11/03/21	9.239	281.98	290.55	-8.57	99.84	67.23	0.90	0.51	24.00
12/03/21	9.274	300.82	309.99	-9.17	99.17	68.49	0.90	0.51	24.00
13/03/21	8.567	282.46	290.62	-8.17	96.32	66.14	0.90	0.51	24.00
ИТОГО:	61.39	2067.1	2128.8	-61.7	95.85	66.29	0.90	0.51	168.0
14/03/21	7.617	258.94	265.92	-6.99	91.08	61.78	0.90	0.51	24.00
15/03/21	6.722	219.40	224.87	-5.47	88.99	58.47	0.90	0.51	24.00
16/03/21	6.459	206.70	211.75	-5.05	88.59	57.46	0.90	0.51	24.00
17/03/21	6.379	201.89	206.64	-4.75	88.61	57.13	0.90	0.51	24.00
18/03/21	6.313	199.84	204.50	-4.67	88.33	56.86	0.90	0.51	24.00
19/03/21	6.341	194.32	198.91	-4.59	89.25	56.73	0.90	0.51	24.00
20/03/21	6.830	211.83	216.97	-5.14	90.75	58.64	0.90	0.51	24.00
ИТОГО:	46.66	1492.9	1529.6	-36.7	89.44	58.31	0.90	0.51	168.0
ИТОГО:	211.23	6815.7	7021.3	+0.0	94.25	63.43	0.90	0.51	672.0
		-205.62		-205.62	30.82				

Общее время работы системы, ч = Tнар. + Tmin + Tmax + Tdtmin + Ttn.
 672.00 672.00 0.00 0.00 0.00 0.00
 Количество тепла, Гкал Q = Qt/c + Qmin + Qmax + Qchw. + Qt/v + Qsan.ут.
 = 211.23 + + + + +

Показания интеграторов на	20/02/21 24:00	20/03/21 24:00	Разность		22/03/21 09:13
Расход тепла Q, Гкал	11256.439	11467.664 ✓	211.225	:	11476.928
Расход теплоносителя M1, т	425624.66	432440.36	6815.70	:	432727.09
Расход теплоносителя M2, т	501778.32	508799.64	7021.32	:	509093.07
Время наработки Tнар, ч	70301.82	70973.81	672.00	:	71007.04
Время наработки Tнер = Tmax + Tmin + Tdt + Ttn, ч			0.00	:	

v2R.40
 Подпись потребителя  _____
 Подпись поставщика _____