

НОМЕР АБОНЕНТА:  
АДРЕС УСТАНОВКИ:

600 ч Ул. Фейтмановская  
Южная, Радужная д.18

Подсчет Ол. тепла

Зав. № 1551476

G1 ДУ50 0.150 - 60.00 мЗ/ч  
G2 ДУ50 0.150 - 60.00 мЗ/ч  
Q = M1(hн - hо)

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ  
за период с 21/07/21 по 20/08/21

ДАТА дд/мм/гг	Q Гкал	M1 т	M2 т	M1-M2 т	Tп С	To С	Pп МПа	Po МПа	Tнар,ч час
21/07/21	0.000	0.00	0.00	+0.00	21.33	20.68	0.91	0.51	24.00
22/07/21	0.213	16.97	17.33	-0.35	63.62	51.15	0.91	0.51	24.00
23/07/21	0.981	121.59	123.53	-1.94	67.98	59.99	0.91	0.51	24.00
24/07/21	0.899	126.50	129.11	-2.61	68.12	61.10	0.91	0.51	24.00
25/07/21	1.052	125.52	128.15	-2.63	68.24	59.95	0.91	0.51	24.00
26/07/21	0.955	126.41	129.04	-2.64	68.17	60.70	0.91	0.51	24.00
27/07/21	0.941	102.80	104.84	-2.04	67.64	58.58	0.91	0.51	24.00
ИТОГО:	5.04	619.8	632.0	-12.2	67.92	59.88	0.91	0.51	168.0
28/07/21	0.821	68.42	70.09	-1.67	68.45	56.54	0.91	0.51	24.00
29/07/21	0.952	69.94	71.59	-1.65	68.95	55.42	0.91	0.51	24.00
30/07/21	0.856	72.54	74.25	-1.71	69.65	57.94	0.91	0.51	24.00
31/07/21	1.037	77.65	79.31	-1.66	71.04	57.77	0.91	0.51	24.00
01/08/21	1.012	79.79	81.51	-1.72	71.53	58.93	0.91	0.51	24.00
02/08/21	1.076	108.22	110.05	-1.83	71.97	62.10	0.91	0.51	24.00
03/08/21	1.014	114.75	116.52	-1.77	70.57	61.81	0.91	0.51	24.00
ИТОГО:	6.77	591.3	603.3	-12.0	70.47	59.10	0.91	0.51	168.0
04/08/21	1.099	114.21	115.97	-1.75	70.50	60.96	0.91	0.51	24.00
05/08/21	0.982	119.89	121.82	-1.94	70.30	62.19	0.91	0.51	24.00
06/08/21	1.029	127.64	129.78	-2.14	70.13	62.15	0.91	0.51	24.00
07/08/21	1.020	128.07	130.16	-2.09	70.15	62.27	0.91	0.51	24.00
08/08/21	1.066	128.18	130.18	-2.00	70.32	62.09	0.91	0.51	24.00
09/08/21	1.050	128.35	130.38	-2.03	70.14	62.04	0.91	0.51	24.00
10/08/21	1.016	129.74	131.77	-2.03	70.21	62.47	0.91	0.51	24.00
ИТОГО:	7.26	876.1	890.1	-14.0	70.25	62.04	0.91	0.51	168.0
11/08/21	0.957	129.46	131.56	-2.10	70.17	62.86	0.91	0.51	24.00
12/08/21	0.990	126.29	128.33	-2.05	70.23	62.47	0.91	0.51	24.00
13/08/21	1.008	129.76	131.93	-2.17	69.93	62.25	0.91	0.51	24.00
14/08/21	1.007	128.55	130.78	-2.23	70.09	62.34	0.91	0.51	24.00
15/08/21	0.994	127.66	129.90	-2.24	70.20	62.49	0.91	0.51	24.00
16/08/21	1.133	128.43	130.72	-2.29	70.25	61.51	0.91	0.51	24.00
17/08/21	0.990	129.06	131.35	-2.28	70.32	62.74	0.91	0.51	24.00
ИТОГО:	7.08	899.2	914.6	-15.4	70.17	62.38	0.91	0.51	168.0
18/08/21	1.121	128.99	131.20	-2.21	70.40	61.80	0.91	0.51	24.00
19/08/21	1.262	127.93	130.04	-2.11	70.27	60.49	0.91	0.51	24.00
20/08/21	1.697	124.86	126.89	-2.03	70.19	56.69	0.91	0.51	24.00
ИТОГО:	4.08	381.8	388.1	-6.3	70.29	59.69	0.91	0.51	72.0
ИТОГО:	30.23	3368.1	3428.1	+0.0	69.84	60.95	0.91	0.51	744.0
			-59.92	-59.92		8.89			

Общее время работы системы, ч = Tнар. + Tmin + Tmax + Tdtmin + Tтн.  
744.00 743.99 0.00 0.00 0.00 0.01

Количество тепла, Гкал Q = Qt/c + Qmin + Qmax + Qов. + Qt/в + Qсан.ут.  
= 30.23 + \_\_\_\_\_ + \_\_\_\_\_ + \_\_\_\_\_ + \_\_\_\_\_ + \_\_\_\_\_

Показания интеграторов на	20/07/21 24:00	20/08/21 24:00	Разность	23/08/21 10:54
Расход тепла Q, Гкал	4455.109	4485.336	30.227 ✓	4489.357
Расход теплоносителя M1, т	124539.07	127907.22	3368.15	128211.10
Расход теплоносителя M2, т	126279.04	129707.11	3428.07	130015.84
Время наработки Tнар, ч	26203.01	26947.01	743.99	27005.91
Время неработы Tнер = Tmax + Tmin + Tdt + Tтн, ч			0.01	

вЗА.11

Подпись потребителя



Подпись поставщика