

НОМЕР АБОНЕНТА:

000 "УК - Стройтрансгазавтоматика"

Подсистема Система 1

ТЭМ-104 Зав.Н 1551476

АДРЕС УСТАНОВКИ:

Южной, Радужная д. 18

G1 ДУ50 0.150 - 60.00 м3/ч

G2 ДУ50 0.150 - 60.00 м3/ч

Q = M1(hm1 - h0)

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ

за период с 21/02/21 по 20/03/21

DATA дд/мм/гг	Q Гкал	M1 т	M2 т	M1-M2 т	Tп С	To С	Pп МПа	Ро МПа	Tнар,ч час
21/02/21	9.062	209.04	209.62	-0.58	102.18	59.00	0.91	0.51	24.00
22/02/21	9.477	224.41	225.84	-1.44	102.39	60.33	0.91	0.51	24.00
23/02/21	10.624	225.94	227.30	-1.35	109.38	62.57	0.91	0.51	24.00
24/02/21	10.651	237.35	239.47	-2.12	108.71	64.04	0.91	0.51	24.00
25/02/21	4.303	97.68	98.50	-0.82	106.12	62.63	0.91	0.51	24.00
26/02/21	4.126	97.92	98.99	-1.07	81.44	39.49	0.91	0.51	24.00
27/02/21	6.021	143.62	144.48	-0.86	86.94	45.13	0.91	0.51	24.00
ИТОГО:	54.26	1236.0	1244.2	-8.2	101.69	57.99	0.91	0.51	168.0
28/02/21	5.978	135.83	137.76	-1.93	88.10	44.20	0.91	0.51	24.00
01/03/21	5.941	133.44	135.25	-1.81	88.92	44.51	0.91	0.51	24.00
02/03/21	5.450	124.28	126.15	-1.87	87.51	43.77	0.91	0.51	24.00
03/03/21	5.930	137.23	138.62	-1.40	89.56	46.47	0.91	0.51	24.00
04/03/21	5.614	126.73	127.69	-0.96	89.20	45.01	0.91	0.51	24.00
05/03/21	6.818	178.88	181.46	-2.57	88.12	50.12	0.91	0.51	24.00
06/03/21	7.464	213.75	215.49	-1.74	87.33	52.53	0.91	0.51	24.00
ИТОГО:	43.19	1050.1	1062.4	-12.3	88.30	47.28	0.91	0.51	168.0
07/03/21	7.504	201.72	202.46	-0.75	89.89	52.81	0.91	0.51	24.00
08/03/21	7.839	213.82	214.89	-1.07	90.65	54.11	0.91	0.51	24.00
09/03/21	8.050	194.82	195.58	-0.76	95.42	54.24	0.91	0.51	24.00
10/03/21	7.730	164.05	164.51	-0.46	97.92	50.95	0.91	0.51	24.00
11/03/21	8.265	177.88	178.38	-0.50	99.04	52.74	0.91	0.51	24.00
12/03/21	8.399	188.73	189.41	-0.68	98.38	54.03	0.91	0.51	24.00
13/03/21	7.858	182.83	184.41	-1.58	95.59	52.75	0.91	0.51	24.00
ИТОГО:	55.65	1323.8	1329.6	-5.8	95.05	53.16	0.91	0.51	168.0
14/03/21	6.351	143.02	144.63	-1.61	90.32	46.04	0.91	0.51	24.00
15/03/21	5.528	123.23	124.04	-0.80	88.19	43.44	0.91	0.51	24.00
16/03/21	5.410	120.94	121.57	-0.62	87.79	43.17	0.91	0.51	24.00
17/03/21	5.571	125.90	126.11	-0.21	87.85	43.71	0.91	0.51	24.00
18/03/21	5.556	128.73	129.09	-0.36	87.62	44.56	0.91	0.51	24.00
19/03/21	5.906	137.71	137.74	-0.03	88.55	45.78	0.91	0.51	24.00
20/03/21	6.646	159.12	159.23	-0.11	90.12	48.47	0.91	0.51	24.00
ИТОГО:	40.97	938.7	942.4	-3.7	88.72	45.19	0.91	0.51	168.0
ИТОГО:	194.07	4548.6	4578.7	+0.0	93.99	51.47	0.91	0.51	672.0
		-30.08	-30.08	42.52					

Общее время работы системы, ч = Tнар. + Tmin + Tmax + Tdtmin + Tтн.  
 744.00 672.00 0.00 0.00 0.00 0.00  
 Количество тепла, Гкал Q = Qt/c + Qmin + Qmax + Qсм. + Qt/в + Qсан.ут.  
 \_\_\_\_\_ = 194.07 + \_\_\_\_\_ + \_\_\_\_\_ + \_\_\_\_\_ + \_\_\_\_\_ + \_\_\_\_\_

Показания интеграторов на	20/02/21 24:00	20/03/21 24:00	Разность	22/03/21 09:20
Расход тепла Q, Гкал	3962.689	4156.760	194.071	4165.300
Расход теплоносителя M1, т	111703.43	116252.03	4548.59	116453.53
Расход теплоносителя M2, т	113294.12	117872.80	4578.67	118074.55
Время наработки Tнар, ч	22616.09	23298.09	672.00	23321.42
Время неработы Tнер = Tmax + Tmin + Tdt + Tтн, ч			0.00	

вЗА.11

Подпись потребителя \_\_\_\_\_

Подпись поставщика \_\_\_\_\_