

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ
 за период с 21/03/22 по 20/04/22

ДАТА дд/мм/гг	Q Гкал	M1 т	M2 т	M1-M2 т	Tп С	To С	Fп МПа	Fo МПа	Tнар,ч час
21/03/22	6.167	198.76	201.64	-2.88	82.37	51.45	0.91	0.51	24.00
22/03/22	6.055	196.29	198.98	-2.69	82.54	51.80	0.91	0.51	24.00
23/03/22	6.066	193.74	196.47	-2.73	82.76	51.56	0.91	0.51	24.00
24/03/22	6.131	192.66	195.41	-2.75	83.29	51.57	0.91	0.51	24.00
25/03/22	5.921	191.99	194.65	-2.66	82.27	51.53	0.91	0.51	24.00
26/03/22	5.826	186.29	188.84	-2.55	82.63	51.45	0.91	0.51	24.00
27/03/22	6.093	176.44	178.80	-2.36	84.10	49.67	0.91	0.51	24.00
ИТОГО:	42.26	1336.2	1354.8	-18.6	82.83	51.31	0.91	0.51	168.0
28/03/22	6.353	169.50	171.89	-2.39	87.37	50.00	0.91	0.51	24.00
29/03/22	6.157	176.92	179.34	-2.42	84.84	50.15	0.91	0.51	24.00
30/03/22	6.149	176.34	178.71	-2.37	85.08	50.32	0.91	0.51	24.00
31/03/22	6.169	176.49	178.85	-2.36	85.17	50.32	0.91	0.51	24.00
01/04/22	6.082	186.33	188.75	-2.43	82.86	50.32	0.91	0.51	24.00
02/04/22	6.215	186.19	188.46	-2.27	83.55	50.27	0.91	0.51	24.00
03/04/22	6.267	183.34	185.68	-2.34	84.36	50.28	0.91	0.51	24.00
ИТОГО:	43.39	1255.1	1271.7	-16.6	84.71	50.24	0.91	0.51	168.0
04/04/22	6.289	183.31	185.69	-2.38	84.64	50.43	0.91	0.51	24.00
05/04/22	6.139	187.64	189.98	-2.35	82.91	50.29	0.91	0.51	24.00
06/04/22	5.993	187.21	189.13	-1.92	82.87	50.96	0.91	0.51	24.00
07/04/22	5.972	190.27	192.24	-1.97	82.40	51.12	0.91	0.51	24.00
08/04/22	5.161	174.02	176.29	-2.27	79.36	49.79	0.91	0.51	24.00
09/04/22	4.303	136.21	138.31	-2.10	79.25	47.75	0.91	0.51	24.00
10/04/22	4.414	139.42	141.66	-2.24	79.04	47.48	0.91	0.51	24.00
ИТОГО:	38.27	1198.1	1213.3	-15.2	81.71	49.86	0.91	0.51	168.0
11/04/22	5.001	154.90	157.31	-2.41	80.59	48.39	0.91	0.51	24.00
12/04/22	5.751	178.73	181.70	-2.98	81.24	49.16	0.91	0.51	24.00
13/04/22	5.789	179.06	182.16	-3.09	81.82	49.59	0.91	0.51	24.00
14/04/22	5.490	179.97	183.17	-3.19	80.28	49.87	0.91	0.51	24.00
15/04/22	5.433	185.08	188.41	-3.33	79.50	50.24	0.91	0.51	24.00
16/04/22	5.752	184.02	187.31	-3.29	81.14	49.98	0.91	0.51	24.00
17/04/22	5.867	180.25	183.50	-3.25	82.13	49.68	0.91	0.51	24.00
ИТОГО:	39.08	1242.0	1263.6	-21.5	80.96	49.59	0.91	0.51	168.0
18/04/22	5.670	185.50	188.84	-3.34	80.32	49.86	0.91	0.51	24.00
19/04/22	4.814	169.85	172.85	-3.00	78.92	50.67	0.91	0.51	24.00
20/04/22	3.589	127.01	129.13	-2.11	77.98	49.81	0.91	0.51	24.00
ИТОГО:	14.07	482.4	490.8	-8.5	79.21	50.13	0.91	0.51	72.0
ИТОГО:	177.08	5513.7	5594.2	+0.0	82.28	50.26	0.91	0.51	744.0
		-80.42	-80.42	32.02					

Общее время работы системы, ч = Tнар. + Tmin + Tmax + Tdtmin + Tтн.
 744.00 744.00 0.00 0.00 0.00 0.00
 Количество тепла, Гкал Q = Qt/c + Qmin + Qmax + Qощ. + Qt/в + Qсан.ут.
 = 177.08 + _____ + _____ + _____ + _____ + _____

Показания интеграторов на	20/03/22 24:00	20/04/22 24:00	Разность	21/04/22 09:10
Расход тепла Q, Гкал	5759.446	5936.525	177.079	5937.822
Расход теплоносителя M1, т	170003.85	175517.58	5513.73	175564.30
Расход теплоносителя M2, т	172158.41	177752.56	5594.15	177800.07
Время наработки Tнар, ч	32033.49	32777.49	744.00	32786.66
Время неработы Tнер = Tmax + Tmin + Tdt + Tтн, ч			0.00	

в.з.а.11

Подпись потребителя _____

Подпись поставщика _____