

НОМЕР АБОНЕНТА:  
АДРЕС УСТАНОВКИ:

ОО «Ул. Строительная»  
Поддача+Р Система 1  
Южной Радунчал 9/18.

ТЭМ-104 Зав.№ 1551476

G1 ДУ50 0.150 - 60.00 м3/ч

G2 ДУ50 0.150 - 60.00 м3/ч

Q = M1(h1 - h0)

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ

за период с 21/06/22 по 20/07/22

ДАТА дд/мм/гг	Q Гкал	M1 т	M2 т	M1-M2 т	Tп С	To С	Pп МПа	Po МПа	Tнар,ч час
21/06/22	1.612	121.84	122.92	-1.09	67.00	53.85	0.91	0.51	24.00
22/06/22	1.704	121.73	122.88	-1.14	67.02	53.10	0.91	0.51	24.00
23/06/22	1.670	121.71	123.01	-1.30	66.92	53.28	0.91	0.51	24.00
24/06/22	1.607	121.52	123.03	-1.51	66.74	53.60	0.91	0.51	24.00
25/06/22	1.553	121.63	123.24	-1.61	66.92	54.23	0.91	0.51	24.00
26/06/22	1.570	121.46	123.09	-1.63	67.05	54.21	0.91	0.51	24.00
27/06/22	1.500	122.34	124.03	-1.69	67.00	54.82	0.91	0.51	24.00
ИТОГО:	11.22	852.2	862.2	-10.0	66.95	53.87	0.91	0.51	168.0
28/06/22	1.467	121.87	123.53	-1.66	67.01	55.06	0.91	0.51	24.00
29/06/22	1.149	93.33	94.59	-1.26	65.29	53.07	0.91	0.51	24.00
30/06/22	1.550	121.94	123.39	-1.44	66.96	54.33	0.91	0.51	24.00
01/07/22	1.446	122.06	123.13	-1.07	66.91	55.14	0.91	0.51	24.00
02/07/22	1.493	122.01	122.94	-0.93	66.88	54.73	0.91	0.51	24.00
03/07/22	1.620	120.01	120.96	-0.95	67.12	53.70	0.91	0.51	24.00
04/07/22	1.586	122.00	123.03	-1.04	66.95	54.04	0.91	0.51	24.00
ИТОГО:	10.31	823.2	831.6	-8.4	66.78	54.34	0.91	0.51	168.0
05/07/22	0.442	44.10	44.51	-0.41	64.36	54.42	0.91	0.51	24.00
06/07/22	0.000	0.00	0.00	+0.00	28.01	31.88	0.91	0.51	24.00
07/07/22	0.390	26.52	26.84	-0.33	59.24	44.72	0.91	0.51	24.00
08/07/22	1.435	121.71	123.62	-1.91	66.91	55.20	0.91	0.51	24.00
09/07/22	1.518	122.34	124.13	-1.79	67.18	54.86	0.91	0.51	24.00
10/07/22	1.538	122.79	124.43	-1.64	67.17	54.72	0.91	0.51	24.00
11/07/22	1.489	121.82	123.46	-1.64	67.51	55.37	0.91	0.51	24.00
ИТОГО:	6.81	559.3	567.0	-7.7	66.59	54.50	0.91	0.51	168.0
12/07/22	1.444	123.16	125.30	-2.14	67.54	55.90	0.91	0.51	24.00
13/07/22	1.322	110.89	112.65	-1.76	65.77	53.98	0.91	0.51	24.00
14/07/22	1.478	123.05	124.65	-1.59	65.49	53.56	0.91	0.51	24.00
15/07/22	1.462	122.83	124.38	-1.54	65.31	53.49	0.91	0.51	24.00
16/07/22	1.461	122.77	124.31	-1.54	65.44	53.63	0.91	0.51	24.00
17/07/22	1.459	122.63	124.02	-1.39	65.56	53.75	0.91	0.51	24.00
18/07/22	1.531	122.59	123.94	-1.34	65.52	53.11	0.91	0.51	24.00
ИТОГО:	10.16	847.9	859.2	-11.3	65.81	53.92	0.91	0.51	168.0
19/07/22	1.561	123.24	124.04	-0.80	65.32	52.74	0.91	0.51	24.00
20/07/22	1.516	124.04	124.50	-0.46	65.60	53.46	0.91	0.51	24.00
ИТОГО:	3.08	247.3	248.5	-1.3	65.46	53.10	0.91	0.51	48.0
ИТОГО:	41.57	3329.9	3368.6	+0.0	66.45	54.05	0.91	0.51	720.0
		-38.63	-38.63	12.40					

Общее время работы системы, ч = Tнар. + Tmin + Tmax + Tdtmin + Tтн.  
744.00 720.00 0.00 0.00 0.00 0.00

Количество тепла, Гкал Q = Qt/c + Qmin + Qmax + Qов. + Qt/в + Qсан.ут.  
= 41.57 + + + + +

Показания интеграторов на	20/06/22 24:00	20/07/22 24:00	Разность	21/07/22 14:20
Расход тепла Q, Гкал	6096.027	6137.602	41.575	6138.463
Расход теплоносителя M1, т	183513.88	186943.81	3329.93	186917.92
Расход теплоносителя M2, т	185836.78	189205.33	3368.55	189279.80
Время наработки Tнар, ч	34238.74	34958.73	720.00	34973.08
Время неработы Tнер = Tmax + Tmin + Tdt + Tтн, ч			0.00	

вЗА.11

Подпись потребителя

Подпись поставщика