

АДРЕС УСТАНОВКИ:

Южная, ул. Раутенберг г. 12

G1 ДУ50 0.150 - 60.00 м3/ч
G2 ДУ50 0.150 - 60.00 м3/ч
Q = M1(hn - ho)

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ
за период с 21/02/22 по 20/03/22

ДАТА	Q	M1	M2	M1-M2	Tn	To	Pn	Po	Tнар,ч
дд/мм/гг	Гкал	т	т	т	С	С	МПа	МПа	час
21/02/22	5.520	147.22	148.54	-1.31	85.22	47.83	0.91	0.51	24.00
22/02/22	5.242	145.53	146.73	-1.21	84.03	48.11	0.91	0.51	24.00
23/02/22	5.540	156.76	157.99	-1.23	83.70	48.46	0.91	0.51	24.00
24/02/22	5.897	163.14	164.51	-1.37	85.30	49.26	0.91	0.51	24.00
25/02/22	6.675	195.79	197.50	-1.70	85.38	51.39	0.91	0.51	24.00
26/02/22	6.601	199.26	200.95	-1.69	84.52	51.50	0.91	0.51	24.00
27/02/22	6.841	195.79	197.37	-1.59	85.37	50.53	0.91	0.51	24.00
ИТОГО:	42.32	1203.5	1213.6	-10.1	84.82	49.77	0.91	0.51	168.0
28/02/22	7.091	187.37	189.14	-1.77	89.30	51.57	0.91	0.51	24.00
01/03/22	7.015	183.91	185.71	-1.80	90.40	52.38	0.91	0.51	24.00
02/03/22	6.959	188.57	190.33	-1.76	88.93	52.14	0.91	0.51	24.00
03/03/22	6.768	186.58	188.31	-1.73	88.14	51.98	0.91	0.51	24.00
04/03/22	6.929	185.85	187.52	-1.68	89.04	51.88	0.91	0.51	24.00
05/03/22	6.856	187.92	189.70	-1.78	88.35	51.98	0.91	0.51	24.00
06/03/22	6.934	185.35	187.18	-1.83	88.54	51.25	0.91	0.51	24.00
ИТОГО:	48.55	1305.5	1317.9	-12.3	88.95	51.88	0.91	0.51	168.0
07/03/22	6.675	193.58	195.53	-1.95	85.27	50.90	0.91	0.51	24.00
08/03/22	6.990	185.10	186.95	-1.85	88.48	50.84	0.91	0.51	24.00
09/03/22	7.205	174.10	175.79	-1.69	92.13	50.87	0.91	0.51	24.00
10/03/22	7.248	171.43	173.07	-1.65	92.20	50.04	0.91	0.51	24.00
11/03/22	7.483	172.26	173.90	-1.65	95.09	51.79	0.91	0.51	24.00
12/03/22	7.241	178.08	179.96	-1.89	92.48	51.94	0.91	0.51	24.00
13/03/22	7.067	185.24	187.29	-2.05	88.58	50.54	0.91	0.51	24.00
ИТОГО:	49.91	1259.8	1272.5	-12.7	90.48	50.99	0.91	0.51	168.0
14/03/22	6.561	192.27	194.86	-2.58	85.09	51.07	0.91	0.51	24.00
15/03/22	6.865	186.20	188.77	-2.57	88.44	51.69	0.91	0.51	24.00
16/03/22	7.032	176.57	179.07	-2.50	91.90	52.20	0.91	0.51	24.00
17/03/22	6.947	177.12	179.61	-2.49	90.58	51.48	0.91	0.51	24.00
18/03/22	6.724	179.58	182.08	-2.51	89.01	51.69	0.91	0.51	24.00
19/03/22	6.731	186.49	189.08	-2.59	87.70	51.72	0.91	0.51	24.00
20/03/22	6.488	194.19	196.77	-2.57	84.09	50.78	0.91	0.51	24.00
ИТОГО:	47.35	1292.4	1310.2	-17.8	88.03	51.51	0.91	0.51	168.0
ИТОГО:	188.13	5061.3	5114.2	+0.0	88.12	51.06	0.91	0.51	672.0
		-52.97	-52.97	37.05					

Общее время работы системы, ч = Tнар. + Tmin + Tmax + Tdtmin + Tтн.
744.00 672.00 0.00 0.00 0.00 0.00

Количество тепла, Гкал Q = Qt/c + Qmin + Qmax + Qощ. + Qt/в + Qсан.ут.
= 188.13 + + + + +

Показания интеграторов на	20/02/22 24:00	20/03/22 24:00	Разность	21/03/22 09:29
Расход тепла Q, Гкал	5571.318	5759.446	188.128 ✓	5761.823
Расход теплоносителя M1, т	164942.60	170003.85	5061.25	170081.35
Расход теплоносителя M2, т	167044.18	172158.41	5114.22	172237.07
Время наработки Tнар, ч	31361.49	32033.49	672.00	32042.98
Время неработы Tнер = Tmax + Tmin + Tdt + Tтн, ч			0.00	

v3A.11
Подпись потребителя 

Подпись поставщика _____