

НОМЕР АБОНЕНТА:
АДРЕС УСТАНОВКИ:

М.У.Р. - Строительная
Южный Вагучинский р.п.

ТЭН-104 Зав.№ 1551476
G1 ДУ50 0.150 - 60.00 м3/ч
G2 ДУ50 0.150 - 60.00 м3/ч
Q = M1(hn - ho)

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ
за период с 21/12/20 по 20/01/21

ДАТА дд/мм/гг	Q Гкал	M1 т	M2 т	M1-M2 т	Tп С	To С	Pп МПа	Po МПа	Tнар,ч час
21/12/20	5.733	131.27	133.27	-2.00	87.72	44.16	0.91	0.51	24.00
22/12/20	6.137	145.58	147.79	-2.21	88.63	46.59	0.91	0.51	24.00
23/12/20	7.071	186.77	189.66	-2.89	89.33	51.59	0.91	0.51	24.00
24/12/20	7.595	215.00	218.17	-3.17	89.67	54.47	0.91	0.51	24.00
25/12/20	6.749	174.46	177.23	-2.77	88.99	50.42	0.91	0.51	24.00
26/12/20	6.063	146.58	148.87	-2.29	88.30	47.05	0.91	0.51	24.00
27/12/20	7.401	202.49	205.60	-3.11	89.13	52.70	0.91	0.51	24.00
ИТОГО:	46.75	1202.2	1220.6	-18.4	88.92	50.15	0.91	0.51	168.0
28/12/20	7.815	228.81	232.24	-3.43	89.90	55.87	0.91	0.51	24.00
29/12/20	7.966	233.88	237.09	-3.20	90.15	56.21	0.91	0.51	24.00
30/12/20	6.843	176.88	179.94	-3.06	88.50	49.92	0.91	0.51	24.00
31/12/20	6.697	167.21	169.88	-2.67	87.70	47.76	0.91	0.51	24.00
01/01/21	6.096	153.50	155.88	-2.37	87.85	48.25	0.91	0.51	24.00
02/01/21	5.952	147.74	150.13	-2.38	87.66	47.49	0.91	0.51	24.00
03/01/21	5.961	147.81	150.11	-2.31	87.58	47.36	0.91	0.51	24.00
ИТОГО:	47.33	1255.8	1275.3	-19.4	88.67	51.09	0.91	0.51	168.0
04/01/21	6.204	154.12	156.44	-2.33	87.55	47.41	0.91	0.51	24.00
05/01/21	6.343	163.90	166.18	-2.28	87.14	48.55	0.91	0.51	24.00
06/01/21	6.922	190.61	193.17	-2.56	87.08	50.88	0.91	0.51	24.00
07/01/21	7.276	204.32	207.32	-3.01	87.82	52.32	0.91	0.51	24.00
08/01/21	7.428	210.52	213.03	-2.51	88.58	53.41	0.91	0.51	24.00
09/01/21	7.944	239.33	241.59	-2.26	89.24	56.17	0.91	0.51	24.00
10/01/21	8.366	255.05	257.01	-1.95	89.99	57.31	0.91	0.51	24.00
ИТОГО:	50.48	1417.8	1434.7	-16.9	88.36	52.86	0.91	0.51	168.0
11/01/21	8.102	245.71	249.26	-3.54	89.02	56.16	0.91	0.51	24.00
12/01/21	8.086	240.37	242.49	-2.12	89.10	55.58	0.91	0.51	24.00
13/01/21	8.091	235.16	238.08	-2.91	89.59	55.31	0.91	0.51	24.00
14/01/21	7.700	209.87	213.10	-3.23	89.67	53.10	0.91	0.51	24.00
15/01/21	8.343	204.96	208.22	-3.26	94.78	54.21	0.91	0.51	24.00
16/01/21	8.335	196.25	199.40	-3.15	93.69	51.35	0.91	0.51	24.00
17/01/21	8.158	182.17	184.98	-2.81	93.05	48.40	0.91	0.51	24.00
ИТОГО:	56.82	1514.5	1535.5	-21.0	91.08	53.69	0.91	0.51	168.0
18/01/21	9.616	199.10	201.88	-2.78	102.66	54.55	0.91	0.51	24.00
19/01/21	11.175	242.68	245.46	-2.78	109.57	63.74	0.91	0.51	24.00
20/01/21	10.081	242.39	246.19	-3.79	103.35	61.94	0.91	0.51	24.00
ИТОГО:	30.87	684.2	693.5	-9.4	105.36	60.43	0.91	0.51	72.0
ИТОГО:	232.25	6074.5	6159.6	+0.0	91.13	53.02	0.91	0.51	744.0
		-85.14	-85.14	38.11					

Общее время работы системы, ч = Tнар. + Tmin + Tmax + Tdtmin + Tтн.
744.00 743.99 0.00 0.00 0.00 0.01

Количество тепла, Гкал Q = Qt/c + Qmin + Qmax + Qощ. + Qt/в + Qсан.ут.
= 232.25 + + + + +

Показания интеграторов на	20/12/20 24:00	20/01/21 24:00	Разность	21/01/21 09:49
Расход тепла Q, Гкал	3468.196	3700.446	232.250	3704.336
Расход теплоносителя M1, т	99523.17	105597.68	6074.50	105697.26
Расход теплоносителя M2, т	100943.31	107102.96	6159.65	107204.15
Время наработки Tнар, ч	21128.11	21872.09	743.99	21881.92
Время неработы Tнер = Tmax + Tmin + Tdt + Tтн, ч			0.01	

в.З.А.11
Подпись потребителя 

Подпись поставщика 