

№ПЕР АДВЕНТА: ООО "УК-Стройтрансдомострой"
 АДРЕС УСТАНОВКИ: Кленогор, Радужный г.д.0.
 Тип изм. дав.н 1247905
 01 Д/50 0.150 - 60.00 13/4
 02 Д/50 0.150 - 60.00 13/4
 Q = M1(h1 - h2)

ВЕДОМОСТЬ ЧЕСТЫ ПАРАМЕТРОВ ТЕПЛОПОТЕРЕНИЯ
 за период с 21/07/21 по 20/08/21

ДАТА ДН/МН/ГН	Q Гкал	M1 т	M2 т	M1-M2 т	Tn °С	Ts °С	Pn Мпа	Ps Мпа	Tпер,ч
21/07/21	0.000	0.00	0.00	+0.00	20.79	17.71	0.91	0.51	24.00
22/07/21	0.433	53.46	53.85	-0.39	58.05	50.04	0.91	0.51	24.00
23/07/21	1.600	303.88	304.85	-0.97	69.39	64.24	0.91	0.51	24.00
24/07/21	1.498	322.13	322.30	-0.17	69.50	64.93	0.91	0.51	24.00
25/07/21	1.559	321.35	322.43	-1.08	69.56	64.79	0.91	0.51	24.00
26/07/21	1.502	323.68	324.59	-0.91	69.50	64.94	0.91	0.51	24.00
27/07/21	1.319	262.43	263.68	-1.25	69.07	64.12	0.91	0.51	24.00
ИТОГО:	7.91	1588.9	1573.5	-4.6	69.03	64.14	0.91	0.51	168.0
28/07/21	1.399	173.37	174.80	-1.44	70.46	62.49	0.91	0.51	24.00
29/07/21	1.374	177.07	178.53	-1.46	70.84	63.16	0.91	0.51	24.00
30/07/21	1.420	187.35	181.90	-5.45	71.54	63.87	0.91	0.51	24.00
31/07/21	1.523	195.89	197.39	-1.51	72.82	65.13	0.91	0.51	24.00
01/08/21	1.545	199.47	201.30	-1.83	73.39	65.74	0.91	0.51	24.00
02/08/21	1.495	239.23	241.12	-1.89	73.41	67.25	0.91	0.51	24.00
03/08/21	1.456	286.53	288.85	-2.32	71.96	66.96	0.91	0.51	24.00
ИТОГО:	10.21	1455.1	1466.9	-11.8	72.14	65.21	0.91	0.51	168.0
04/08/21	1.497	227.13	229.56	-2.44	71.85	66.76	0.91	0.51	24.00
05/08/21	1.461	300.17	302.74	-2.57	71.66	66.87	0.91	0.51	24.00
06/08/21	1.550	322.23	324.85	-2.57	71.42	66.69	0.91	0.51	24.00
07/08/21	1.469	322.15	324.54	-2.39	71.40	66.92	0.91	0.51	24.00
08/08/21	1.503	320.56	322.83	-2.25	71.58	66.97	0.91	0.51	24.00
09/08/21	1.415	321.50	323.57	-2.07	71.43	67.11	0.91	0.51	24.00
10/08/21	1.447	326.03	329.03	-2.00	71.50	67.14	0.91	0.51	24.00
ИТОГО:	10.33	2199.3	2216.1	-16.3	71.54	66.93	0.91	0.51	168.0
11/08/21	1.394	325.59	327.95	-2.36	71.47	67.33	0.91	0.51	24.00
12/08/21	1.381	318.56	320.83	-2.27	71.53	67.29	0.91	0.51	24.00
13/08/21	1.395	327.34	329.53	-2.19	71.30	67.11	0.91	0.51	24.00
14/08/21	1.449	324.62	327.00	-2.38	71.41	67.03	0.91	0.51	24.00
15/08/21	1.516	322.26	324.42	-2.16	71.49	66.87	0.91	0.51	24.00
16/08/21	1.477	324.64	326.54	-1.90	71.62	67.15	0.91	0.51	24.00
17/08/21	1.404	321.78	323.50	-1.72	71.72	67.44	0.91	0.51	24.00
ИТОГО:	10.01	2264.8	2279.8	-15.0	71.51	67.17	0.91	0.51	168.0
18/08/21	1.472	322.90	324.85	-1.95	71.74	67.26	0.91	0.51	24.00
19/08/21	1.447	324.72	326.89	-2.11	71.64	67.27	0.91	0.51	24.00
20/08/21	1.430	325.66	327.59	-1.93	71.47	67.18	0.91	0.51	24.00
ИТОГО:	4.35	973.3	977.3	-4.0	71.62	67.24	0.91	0.51	72.0
ИТОГО:	42.81	8482.0	8535.6	-50.6	71.18	66.21	0.91	0.51	744.0
		53.60		-53.60		4.96			

Общее время работы системы, ч = Тпер. + Tmin + Tmax + Tdt Tmin + Тн.

743.99 743.99 0.00 0.00 0.00 0.00

Количество тепла, Гкал Q = G/c + Tmin + Tmax + Tsmin + Gt/c + Gdmin + Gt

= 42.81 + 4 + 7 + 4 + 0.01 + 0.01 + 0.01

Показания интеграторов на 20/07/21 24:00	20/08/21 24:00	Расходность	23/08/21 11:14
Расход тепла Q, Гкал	11360.860	11403.650	42.800 ✓
Расход теплоносителя M1, т	474961.07	483443.08	0102.01
Расход теплоносителя M2, т	500669.20	509204.80	8335.60
Время наработки Тпер, ч	75393.17	76050.16	743.99
Время наработки Тпер = Tmax + Tmin + Tdt + Тн, ч		0.01	76109.40

